



San Ramon Valley Unified School District

3280 Crow Canyon, San Ramon CA 94538
(925) 824-1834 Phone | (925) 866-1706 Fax
www.srvusd.net

May 5, 2017

Addendum/Clarification No. 3 **Item Bid: Seal Coating & Localized Pavement Repair at Various Sites** **RFB# 747**

The following clarifications, changes, additions, deletions and corrections hereinafter set forth shall apply to the Bid Documents for this project and shall be made a part thereof and subject to all the requirements thereof, as if originally specified and/or shown.

NOTE: SUBMITTED QUESTIONS IN BLACK FONTS. ANSWERS IN BLUE FONTS.

Item 1

CLARIFICATION: In addendum 1 and 2 there were questions concerning Skin Patch specifications. Addendum 2 referred bidders to section 32 12 16.07 - HMA Fill. In that specifications the type of asphalt and installation methods are covered. No where in the plans or the technical specifications is the asphalt depth for the skin patched locations provided.

ANSWER:

Average is 1". Will depend on size of area. Will depend on ruts.

End of Addendum

When submitting your bid, please be sure to acknowledge the receipt of all addenda on the form of proposal.

A handwritten signature in black ink that reads "JGacusan".

Jasmine R. Gacusan, CPPO
Director of Purchasing,
Duplicating & Warehouse